



May 07, 2021

Generac Power Systems, Inc.
Nikhil Nagpal
Product Manager – Transfer Switches

Dear Nikhil Nagpal and Sie Teong Lim,

The Electric Distribution Standards and Meter Engineering departments in Pacific Gas & Electric (PG&E) Company, have reviewed the two Generac electric meter panels with a built in automatic transfer switch. I would like to inform you that PG&E has approved this specific equipment for use in our service territory, effective today May 07, 2021.

This approval is only for the models and part numbers listed here. This Generac equipment must be supplied by a PG&E underground service and only accept ringed meter panels. PG&E does not accept ringless meter panels and these meter panels are currently not allowed with an overhead service.

Any modifications or changes to the Generac equipment described here will require another review and approval by the PG&E personnel listed below.

PART NUMBER	DESCRIPTION	MODEL#	MANUAL
A0000815464	AV 200A ATS ILC 3R W/METER SOCKET	RXGUW200A3	A0000529825
A0001459052	ASSY 200A 240V SE METERATS 42CKT ILC CES	CXGUW200A301	A0001467063

This approval letter supersedes all previous letters and approvals.

For further questions please contact,

Daniel Jantz, Engineering Standards Technical Specialist Principle;
Electric Distribution Engineering Standards, 408-365-2206, DWJ7@pge.com
Pacific Gas and Electric Company

Albert Pham, Senior Advising Metering Engineer, 415-973-6412, A1P5@pge.com
Pacific Gas and Electric Company